

Water Drop Kinetic Energy and Momentum Measurement Considerations

Steven E. Hinkle
ASSOC. MEMBER
ASAE

ABSTRACT

The impulse applied to a surface from water drop impact can be measured experimentally by recording and integrating impact force over time. A momentum number, defined as measured impulse divided by the drop's momentum, is a dimensionless physically-based parameter which can be used for modeling soil movement due to water drop impact. Impact forces were measured and integrated over time and the momentum number equals one for a smooth-wet or a rough surface. Accurate impulse measurements do not require sensors with fast dynamic response or calibration, but resonant frequencies must be sufficient to minimize signal amplification. The factors to be considered when measuring impulse or work from water drop impact are identified.

INTRODUCTION

The impact of falling water drops from rainfall or sprinkler irrigation systems has become an important research topic due to its destructive effects on the surface structure of soils. The analysis of a water drop striking a soil surface can be separated into two areas: the fluid mechanics of the water drop during impact, and the mechanical properties of soil under impact loading. The objective of this article is to analyze the fluid mechanics of water drops striking a rigid surface using a whole-drop approach and the principles of kinetic energy, work, momentum and impulse. Impact sensor frequency response and data acquisition sampling rate requirements are also analyzed.

Some researchers (Bisal, 1960; Bubenzer and Jones, 1971; Rose, 1960; Wischmeier and Smith, 1958) have measured soil surface destruction parameters such as soil splashed, depth of soil seal or reduction of infiltration rate and empirically calibrated it to a parameter that usually included drop size, velocity, momentum or kinetic energy. Other researchers (Imaynitov et al., 1966; Imeson et al., 1981; Kinnell, 1972, 1976; Mikhaylovskaya, 1964) used empirically based impact sensors that produced some form of output signal that varied with drop size and velocity. However, no conclusive independent parameter for the dynamic characteristics of a water drop at impact was determined from these empirically based experiments. These

experiments determined that drop size or mass and impact velocity are the most significant variables affecting water drop impact and subsequent soil surface destruction. Calibrations of soil parameters or sensor output to drop size, mass or velocity were generally of the form:

$$Y = a d^{b1} m^{b2} v^{b3} \dots\dots\dots [1]$$

- where
- Y = soil parameter or sensor output
 - d = drop diameter
 - m = drop mass
 - v = drop velocity
 - a,b1,b2,b3 = regression constants.

Since kinetic energy and momentum are calculated from drop mass and velocity, they are a combined parameter for these variables, but have no specific significance to the output from an empirically-based impact sensor or to the soil destruction parameters.

Physical Significance of Momentum and Kinetic Energy

Momentum and kinetic energy are significant because they are the result of integrating Newton's Second Law with respect to time or displacement, respectively, as follows:

$$F = \frac{d(mv)}{dt}, \text{ Newton's Second Law} \dots\dots\dots [2]$$

and integrating with respect to time:

$$\text{Impulse, } Ft = \Delta mv, \text{ Momentum change} \dots\dots\dots [3]$$

or integrating with respect to displacement:

$$\begin{aligned} \int F ds &= \int \frac{d(mv)}{dt} ds \\ &= d(mv) v \\ &= mv dv, \text{ with constant mass} \end{aligned}$$

$$\text{Work, } Fs = \Delta \frac{1}{2} mv^2, \text{ Kinetic Energy Change - Losses} \dots\dots\dots [4]$$

Consequently, impulse is applied to a surface due to a change in momentum, and work is applied due to a change in kinetic energy minus any energy losses such as inelastic deformation or increased water temperature. As independent parameters, momentum or kinetic energy

Article was submitted for publication in September 1988; reviewed and approved for publication by the Soil and Water Div. of ASAE in January 1989. Presented as ASAE Paper No. 88-2136.
Contribution from the USDA-Agricultural Research Service.
The author is: STEVEN E. HINKLE, Agricultural Engineer, USDA-Agricultural Research Service, Akron, CO.

have specific physically-based significance only if they are compared to measured impulse or work, respectively, that is applied to the impact surface.

A similar result is obtained from dimensional analysis of water drop impact. Considering only perpendicular impact with the surface and ignoring the viscosity and surface tension of water and the acceleration of gravity, the significant variables are:

- W = work, [FL]
- I = impulse, [FT]
- ρ = liquid density, [FT²L⁻⁴]
- v = impact velocity, [LT⁻¹]
- d = drop density, [L].

Dimensionless numbers are generated by combining these variables so that dimension is eliminated. The repeating variables used are; ρ to eliminate force, v to eliminate time, and d to eliminate length. Combining ρ , v and d with W and I individually results in:

$$\frac{W}{\rho v^2 d^3} \quad \text{and} \quad \frac{I}{\rho v d^3}$$

Acceleration of gravity is significant when the weight of the water drop is not negligibly less than the force of impact. For the impact force measurements, water drop weight was less than one-thousandth of peak impact force and was not considered significant. Viscosity forces and surface tension may vary impact forces and if they are not negligible compared to inertia forces, then their effect on total impact force can be significant and variable since the viscosity and surface tension of water can vary by 25% and 2.5% over a 10°C temperature range, respectively. For the impact force measurements, water temperature varied by only a couple degrees, so viscosity and surface tension were not included in the analysis. If viscosity, surface tension and acceleration of gravity were included in the dimensional analysis, the Reynolds, Weber and Froude Numbers would have been generated, respectively.

Recognizing that the volume of a sphere equals $\pi d^3/6$ and that mass equals density times volume, the two dimensionless numbers are proportional to:

$$\frac{W}{\frac{1}{2}mv^2} \quad \text{and} \quad \frac{I}{m v}$$

which are the ratios to work to kinetic energy, and impulse to momentum, respectively. These ratios will be referred to as Kinetic Energy Number and Momentum Number, respectively. If either work or impulse can be measured, then a physically-based analysis of these factors to kinetic energy or momentum can be conducted instead of empirically-based analyses.

Schleusener and Kidder (1960) measured the work done by water drops to deflect a target mounted on a cantilever beam. They were able to measure the strain energy stored in the beam, which is that portion of the drops' kinetic energy that is converted to work (applied force times the displacement of the impact target).

METHODS OF IMPULSE MEASUREMENT

Impulse, impact velocity and drop mass can be measured so that a physically-based impulse and momentum analysis can be made of water drop impact. The impulse due to water drop impact was measured for three different surface conditions. Impact forces were measured with a Kistler* model 9712A5 piezoelectric force transducer (impact sensor) which has a resonant (no load) frequency of 70 kHz, a resolution of 0.89 mN and a linearity of $\pm 1\%$. This sensor was calibrated statically with a known weight. The calibration was 4.50 N/v $\pm 0.08\%$ N/v standard deviation.

Circular impact plates of 15 to 20 mm diameter were mounted on this sensor to simulate different surface conditions. Three distinct surface conditions were tested. A smooth surface plate was used for two surface conditions; one with the surface dry and the other with residual water remaining on the surface from previous water drop impacts. A second plate with gravel particles bonded to the plate was used to simulate a rough surface condition. The gravel particles were those sieved out between Tyler Standard Screen No. 7 and 8, and which have an average particle size of 2.58 mm. Residual water also remained on the gravel plate during impact measurements.

The impact plates were mounted on the sensor with a small bolt. The additional mass of the bolt and an impact plate further reduces the resonant frequency of the sensor. The surfaces of piezoelectric sensors exhibit negligible displacement due to impact and are considered essentially rigid. However, they are still treated as a spring-mass system. The resonant frequency of an oscillating system of the first order with no damping (Derrick and Grossman, 1976) is calculated by:

$$f_r = \frac{1}{2\pi} (C/m)^{1/2} \dots \dots \dots [5]$$

where

- f_r = resonant frequency, kHz
- C = spring stiffness, N/ μ m
- m = oscillating mass, kg.

The Kistler 9712A5 sensor has a "rigidity" or spring stiffness of approximately 875 MN/m, so with a resonant frequency of 70 kHz, its oscillating mass without a plate or the mounting bolt is approximately 4.5 g. The bolt mass was 0.7 g and the mass of the plates was less than 2.1 g each resulting in a combined mass of less than 7.3 g. Therefore, the resonant frequency of the system (sensor, bolt and plate) was always greater than 55 kHz, as calculated from $m \leq 7.3$ g and $C = 875$ MN/m in equation [5].

The maximum operating frequency for dynamic transducers is defined as the frequency at which signal amplitude is $\leq 5\%$ of resonant frequency (Hugli, no date). For quartz piezoelectric transducers such as the Kistler model 9712A5, this maximum frequency is 22% of resonant frequency. Therefore, for this system the maximum frequency of force loading on the sensor is 12 kHz which has a period of 83 μ s. The maximum force loading rate from water drop impact occurs from initial

*The mention of trades names or commercial products does not constitute their endorsement or recommendation for use by the USDA-ARS.

impact to the time of peak force, is sinusoidal in shape, occurs between 13 to 22 μ s. Time of peak force for a 3.83 mm diameter drop falling at 8.75 m/s is 19 μ s (Nearing et al., 1986). This zero to peak force loading is similar to the first quarter period of a sine wave, so time to peak force is approximately one-fourth of the signal period. Therefore, the sensor can measure water drop impact with times to peak force $\geq 21 \mu$ s. For the impact force measurements, 3.83 mm water drops falling from 1.5 m with an impact velocity of 5.00 m/s were used which should exhibit times to peak force $\geq 21 \mu$ s or signal frequencies less than 12 kHz.

The minimum operating frequency is determined by the low-frequency time constant which in this study for the sensor and coupler together is 7 s. This operating frequency will only affect signals with frequencies less than one hertz by causing the output signal of the sensor to drift toward zero and cause erroneous measurement. Since signal frequencies are close to 12 kHz, the low frequency time response of the sensor does not need to be considered. The 3.83 mm drops were produced with a 16 gauge syringe needle with the tip cut squarely, and drop size and mass (29.4 mg) were determined by weighing a known number of drops. Drop velocity was measured by a double-ring electrostatic method (Hinkle et al., 1987).

The sensor was connected to and powered by Kistler's model 5112 piezotron coupler, which is AC coupled to reduce output signal noise. The coupler has a distorting or filtering effect on the signal that is dependent upon the sensor driving current, cable capacitance and signal amplitude. For the 4-m cable that was used between the sensor and coupler, having a 2-ma driving current, and 5 volts peak output, all signals less than 160 kHz were unaffected. Since the output signals for the water drops measured had frequencies \leq kHz, no high-frequency filtering was required.

The impact force signals were measured and recorded with a Cyborg Isaac 2000 analog-to-digital recorder connected to a microcomputer. Cyborg's Discovery and Fastscanner software were used to control the Isaac 2000 recorder, subtract out any nonzero baseline, smooth the recorded signal and integrate the signal over time to obtain measured impulse. Experimental considerations, namely impact sensor high-frequency response, and the sampling rate of measured impact force and its integration over time will be analyzed in the following sections. An analysis of force integrated over displacement to obtain work would be similar and is not included.

Dynamic Response Analysis

In addition to loading piezoelectric sensors at frequencies sufficiently below the resonant frequency as discussed, the rise time or the time to respond to a signal input is also an important dynamic characteristic which should be considered. For Kistler sensors, the rise time is defined as the time for the output signal to increase from 10 to 90% of a step-increase input signal and is approximately 0.35 divided by the resonant frequency. The Kistler 9712A5 sensor has a rise time of approximately 6 μ s. For water drop impact, greater rise times cause the output signal to have greater times to peak force and lower peak forces than the actual input signal. However, if impact forces are integrated over

time, rise time has little effect on measured impulse as will be shown.

The force versus time relationship for drops as shown by Nearing et al. (1986) were modeled by a linear rise to peak force, then an exponential decline to zero force, as follows:

$$f = kt, \quad 0 \leq t \leq t_p \dots\dots\dots [6]$$

$$f = c + ae^{bt}, \quad t > t_p \dots\dots\dots [7]$$

- f = input force, [F]
- t = time, [t]
- t_p = time of peak force, [T]
- a, b, c, k = constants.

The constant, c, was set equal to -0.01 so that force would equal zero between 0.5 and 1 ms and not be asymptotic. An example impact force model was obtained by letting $k = 0.0066$, $a = 1.13$, $b = -0.0075$, and time to peak force equal to 15 μ s. This example model was used for the dynamic response analysis and predicts a maximum relative force equal to 1 with the independent variable, time, in μ s.

The dynamic response of a first-order instrument is calculated from the following relationship (Bass, 1971), and an equation for the input to the instrument, g(t):

$$T \frac{dy}{dt} + y = g(t) \dots\dots\dots [8]$$

where

- y = sensor output
- T = time constant, [T]
- g(t) = sensor input.

Equation [8] states that the time constant multiplied by rate of change of the sensor output over time plus sensor output equals sensor input. Time constants generally characterize the low-frequency baseline drift of sensors. The concept of a time constant can also characterize the high-frequency rise time.

For a step increase, g(t) in equation [8] equals a constant, y_c , and the solution to equation [8] is:

$$y/y_c = 1 - e^{-t/T} \dots\dots\dots [9]$$

Substituting the boundary conditions of 10% and 90% signal rise time and with the time difference equal to the rise time results in the high-frequency time constant being approximately 50% of the rise time.

The output response of piezoelectric sensors determined by substituting equation [6] and [7] for g(t) in equation [8] and solving, is as follows:

$$f_o = kt - kT + kte^{-t/T}, \text{ for } 0 \leq t \leq t_p \dots\dots\dots [10]$$

$$f_o = c + \frac{a}{Tb + 1} e^{tb} + e^{(t_p - t)/T} (kt_p - c - \frac{a}{Tb + 1} e^{t_p b}),$$

$$\text{for } t > t_p \dots\dots\dots [11]$$

where

- f_o = the output response (force) from the sensor, [F].




Fig. 1—Simulated sensor output responses to a linear-exponential simulation of water drop impact forces.

The output response for various sensor rise times are shown in Fig. 1 along with output from equation [6] and [7], using the example model coefficients. As rise times increase, recorded peak forces decrease and the times to peak force increase.

Actual impact forces do not peak so abruptly but are more sinusoidal shaped, so the sine function was substituted for $g(t)$ in equation [8], with the solution being:

$$f_o = \frac{\sin(ht) - hT\cos(hT) + hTe^{-t/T}}{1 + h^2T^2} \dots \dots \dots [12]$$

with h equal to $\pi/2$ divided by the time to peak force. The sine function and the output from equation [12] for various rise times are shown in Fig. 2. The relative output peak forces and times to peak force are shown in Table 1. Actual output forces and times have values between those predicted by the two simulations. Piezoelectric sensors generally have rise times less than $10 \mu s$, so recorded peak forces may be up to 10% less, and times to peak force 50% greater than that of the actual force signal. However, peak forces could be 5% greater due to signal frequencies near the 5% signal amplification limit as previously discussed. Actual changes in amplitude and time lag of the output signal can be determined from a dynamic calibration, generally done using a shock tube.

The simulated responses of measured impact forces for different rise times show that integrated impulse is virtually the same for rise times up to at least $80 \mu s$. Impulse was calculated by integrating equations [10] and




Fig. 2—Simulated sensor output responses to a sine-wave simulation of water drop impact forces.

TABLE 1. Simulated peak forces and times to peak force for water drop impact from linear-exponential and sine functions

Rise time, μs	Time to Peak Force, μs		Peak Force, relative	
	linear-exp	sine-wave	linear-exp	sine-wave
0	15	15	1.000	1.000
2.5	18	15.25	0.978	0.992
5	21	17.50	0.957	0.968
10	26	19.50	0.917	0.894
20	36	22	0.849	0.744

[11] from time zero to the time when output force again equaled zero. Calculated impulse for the six response curves in Fig. 1 decrease slightly with increasing rise times. All actual impulses are greater than 99.94 percent of the integrated impulse using input force equations [6] and [7]. Consequently, the rise time of a piezoelectric sensor has little effect on measured impulse from water drop impact, even though peak force and time to peak force could be affected significantly. By a similar analysis, if impact forces can be integrated with respect to displacement, then work applied to a surface could be measured and the dynamic response of the sensor may also have little effect on integrated work.

Sampling Rate Requirements for Impulse Measurement

Even though sensors with short rise times are not required for measuring impulse, the sampling rate of the data acquisition system must be fast enough to minimize potential integration error. Assuming that measurement of the output signal from the sensor is not triggered by the output signal itself, integration can start at the last zero data point and end when force again equals zero. Using trapezoidal integration, the potential error of the integrated value can be significant if the sampling rate is too slow. An example of the integration error of equation [6] and [7] at a 10 kHz sampling rate for the two most extreme situations is shown in Fig. 3.

Force integrated over time has its maximum value greater than actual integration when the first non-zero data point is peak force. Minimum integrated value less than actual integration occurs when the first zero end point is the time of impact. Integrations starting at all other times will have errors between these extreme errors. The potential error is reduced if the ratio of sampling rate to signal frequency is increased. Maximum potential integration errors, shown up to 5%,




Fig. 3—Graphical example of potential integration error of water drop impact forces.




Fig. 4—Potential error of integrating water drop impact forces over time.

for various sampling rates and signal frequencies are shown in Fig. 4. Since the sensor has a linearity of $\pm 1\%$, acceptable integration error can be 1% also.

A general rule for data acquisition is that sampling rates should be at least twice the signal frequency. For any single integration of water drop impact forces over time, this rule will minimize the error to less than 0.5% for signal frequencies greater than 30 kHz. However, measured times to peak force range from 13 to 22 μs (Nearing et al., 1986), which are equivalent to signal frequencies of 11.4 to 19.2 kHz assuming the force loading to peak force is similar to the first quarter of a sine wave. For these slower signal frequencies, the sampling rate should be much greater than twice the signal frequency. Sampling rates greater than 60 kHz will minimize potential impulse integration error to less than 0.3% in the 11.4 to 19.2 kHz signal frequency range.

RESULTS AND DISCUSSION

Measured impulse for 3.83 mm drops falling from 1.5 m height with a velocity, for the three different impact surface conditions are listed in Table 2. The sampling rate was 100 kHz. The standard deviations were determined from 10 replications/surface condition. Peak force and time to peak force could not be determined accurately due to oscillation of the output signal near the time of peak force. This oscillation is due to slight vibration of the plate (Kistler, 1988). These oscillations had a period of 110 to 120 μs , so the 100 kHz sampling rate was sufficient to record them. Figure 5 presents a sample recording clearly indicating the output oscillations for the rough surface condition. The software package (Discovery) was able to smooth the signal so that

TABLE 2. Measured impulse and calculated momentum numbers for three impact surface conditions

Impact surface	Impact Momentum, N- μs	Impact impulse, N- μs			Momentum Number
		Mean	n	S.D.	
Smooth, dry	147.5	147.0	10	2.8	1.00
Smooth, wet	147.5	190.7	10	9.8	1.29
Rough, 2.58 mm average surface particle size	147.5	206.2	10	6.0	1.40

the end point of integration could be determined more accurately. The curve to the right in Fig. 5 presents signals which were smoothed by a factor equivalent to a 5 kHz low-pass filter which did not affect the integrated value as determined by tests with standard geometric-shaped signals.

A calculated momentum number of approximately 1.0 for the smooth dry surface shows that only the impulse caused by the drop's momentum is applied to the surface and that splash is essentially horizontal. A change in momentum perpendicular to the surface must equal the applied impulse because the water drops were impacted perpendicular to the surface and impact forces were measured perpendicular to the surface.

Momentum number values greater than 1.0 for the smooth-wet surface and the rough surface show that additional forces are absorbed by those impact surfaces. The additional forces applied to the surface are caused by equal and opposite forces applied to the water by the surface that lifts the water up into a non-horizontal splash. The perpendicular component of the momentum of the splashed water should be equal to the additional impulse that is measured by the sensor.

The amount of forces, impulse or work applied to a soil surface is greatly affected by the surface conditions. Soil loss or displacement should be more directly related to forces, impulse or work applied to soil surfaces. Thus, soil loss can vary greatly for different surface conditions. Earlier researchers doing empirically-based impact experiments with soils could not make definite conclusions about whether soil loss should be a function of a water drop's momentum or kinetic energy because they did not quantify soil surface roughness and include it in their analyses. Empirical studies correlating soil loss to either kinetic energy or momentum should account for the relationship between work and kinetic, or impulse and momentum due to surface conditions. Consequently, empirical studies need to also correlate soil loss to surface roughness or splash angle, in lieu of measured impulse or work applied to the soil surfaces. These factors suggest that applied impulse or work should be correlated more closely to soil loss than momentum or kinetic energy because impulse or work better represents the total forces applied to the soil surface.




Fig. 5—An example recording of the forces of a water drop impacting the rough surface with the recorded signal on the left and the same signal smoothed on the right.

Sensor Limitations

A piezoelectric sensor can be used by measuring the impulse of whole drops at relatively slow impact velocities. Raindrops and sprinkler drops, though, may have velocities up to 9.1 m/s at sea level to 10.3 m/s at 2 000 m elevation (Hinkle et al., 1987). Measuring impulse for water drops with these impact velocities would require a sensor with greater resonant frequency or less oscillating mass. Times to peak force for these velocities may be as short as 10 μ s or a signal frequency of 25 kHz, which would require a sensor resonant frequency of at least 114 kHz. The Momentum Number, as defined, should have the same value for any impact velocity for a specific drop size and surface roughness, assuming viscosity and surface tension are negligible.

Sensors with greater resonant frequencies have smaller impact surfaces. Larger diameter surfaces increase the oscillating mass which subsequently reduces their resonant frequency. Reducing the mass of the plate would require some reduction of the diameter of the plates which cannot be reduced much below 15 mm without missing some of the flow regime during impact, especially for impact angles less than perpendicular. So a trade-off exists between impact surface size and resonant frequency.

High-frequency response characterized by short rise times is not essential for determining impulse because the value of the integrated force signal is essentially unchanged over a range of rise times. However, rise time is inversely related to resonant frequency which is the major limiting factor to measuring water drop impact forces. If actual peak forces and times to peak force are of concern, then the time-lag and peak signal decrease due to dynamic time-response (rise times > 0) need to be determined by a dynamic calibration for a sensor without any oscillation or signal noise.

CONCLUSIONS

Impulse measured from water drop impact and momentum calculated from measured impact velocity and drop mass enables a physically-based analysis of water drop impact. Piezoelectric sensors have sufficient dynamic response to accurately measure impulse and have impact surfaces large enough to receive the entire water flow regime. However, sensors with greater resonant frequencies are needed to measure the largest (up to 6 mm) water drops at their terminal rainfall velocities. The potential error of integrating water drop impact forces over time is less than 0.3% if sampling rates are greater than 60 kHz for a typical range of water drop impact signal frequencies. If oscillations due to

impact plate vibrations are present on the output signal, sampling rates should probably be at least 100 kHz.

A momentum number of 1.0 for the smooth-dry plates shows that the change of a water drop's momentum perpendicular to the plate is caused by an equal and opposite force between the water and the plate, as defined by Newton's Second Law. Momentum numbers greater than 1.0 were calculated for surfaces with residual water or roughness. Values above one result from greater measured impulse due to the additional impact forces needed to lift the water into a non-horizontal splash that has a perpendicular component of momentum. The momentum number should be a better basis for modeling soil loss parameters than kinetic energy or momentum because it represents the physically-based relationship between drop size, impact velocity, surface conditions and total forces applied over the time of impact.

References

1. Bass, H.G. 1971. *Introduction to Engineering Measurements*. Maidenhead, Berkshire, England: McGraw-Hill Publishing Co.
2. Bisal, F. 1960. The effect of raindrop size and impact velocity on sand splash. *Canadian Journal of Soil Science* 40:242-245.
3. Bubbenzer, G.D. and B.A. Jones, Jr. 1971. Drop size and impact velocity effects on the detachment of soils under simulated rainfall. *Transactions of the ASAE* 14(4):625-628.
4. Derrick, W.R. and S.I. Grossman. 1976. *Elementary Differential Equations with Applications*. Addison-Wesley Publishing Co.
5. Hinkle, S.E., D.F. Heermann and M.C. Blue. 1987. Falling water drop velocities at 1570 m elevation. *Transactions of the ASAE* 30(1):94-100.
6. Hugli, H.W. (No date). *Frequency response of piezoelectric transducers. A practical approach*. Amherst, New York: Kistler Instrument Co.
7. Imaynitov, L.M., V.V. Mikhaylovskaya and B.F. Etveev. 1966. Airborne and radiosonde instruments for measuring raindrop size. *Instruments and Methods for Meteorological Observation, Israel Program for Scientific Translation* 1370:283-291.
8. Imeson, A.C., R. Vis and E. deWater. 1981. The measurement of water-drop impact forces with a piezo-electric transducer. *Catena* 8:83-96.
9. Kinnell, P.I.A. 1972. The acoustic measurements of water-drop impacts. *Journal of Applied Meteorology* 11:691-694.
10. Kinnell, P.I.A. 1976. Some observations of the Joss-Waldvogel rainfall disdrometer. *Journal of Applied Meteorology* 15:499-502.
11. Kistler Staff. 1988. Personal communication. Kistler Instrument Co., Amherst, New York.
12. Mikhaylovskaya, V.V. 1964. Theory of measuring the size of raindrops by acoustic method. *Soviet Hydrol. Selected Papers* 1:85-90.
13. Nearing, M.A., J.M. Bradford and R.D. Holtz. 1986. Measurement of force vs. time relations for waterdrop impact. *Soil Science Society of America Journal* 50:1532-1536.
14. Rose, C.W. 1960. Soil detachment caused by rainfall. *Soil Science* 89(1):28-35.
15. Schleusener, P.E. and E.H. Kidder. 1960. Energy of falling drops from medium-pressure irrigation sprinkler. *Agricultural Engineering* 41(2):100-102.
16. Wischmeier, W.H. and D.D. Smith. 1958. Rainfall energy and its relationship to soil loss. *Transactions of the American Geophysical Union* 39(2):285-291.